



**South Jersey
Water Test, u.c.**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

YMCA of Vineland
1159 East Landis Avenue
Vineland, NJ 08360
856-691-0030 x 106

www.njwatertest.com
NJ DEP Certified Lab # 08086

Sample Location: Field Reagent Blank Date Sampled: 05/12/21 Time Sampled: 04:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106859					
Lead	13-MAY-2021 20:56	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Kitchen Sink Date Sampled: 05/12/21 Time Sampled: 04:43

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106860					
Lead	13-MAY-2021 21:03	3.86	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Sall Sink #1 Date Sampled: 05/12/21 Time Sampled: 04:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106861					
Lead	13-MAY-2021 21:09	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Sall Sink #2 Date Sampled: 05/12/21 Time Sampled: 04:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106862					
Lead	13-MAY-2021 21:16	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:54	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Girls Sink #1 Date Sampled: 05/12/21 Time Sampled: 04:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106863					
Lead	13-MAY-2021 21:23	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:54	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Girs Sink #2 Date Sampled: 05/12/21 Time Sampled: 04:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106864					
Lead	13-MAY-2021 21:29	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:55	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

05/19/2021

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

YMCA of Vineland
1159 East Landis Avenue
Vineland, NJ 08360
856-691-0030 x 106

www.njwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Boys Sink #1

Date Sampled: 05/12/21

Time Sampled: 04:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106865					
Lead	13-MAY-2021 21:36	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:55	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Boys Sink #2

Date Sampled: 05/12/21

Time Sampled: 04:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106866					
Lead	13-MAY-2021 21:42	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:56	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

05/19/2021

Date