



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

YMCA of Vineland
1159 East Landis Avenue
Vineland, NJ 08360
856-691-0030 x 106

www.njwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent Blank Date Sampled: 05/12/21 Time Sampled: 04:40

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106859					
Lead	13-MAY-2021 20:56	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Kitchen Sink Date Sampled: 05/12/21 Time Sampled: 04:43

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106860					
Lead	13-MAY-2021 21:03	3.86	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Sall Sink #1 Date Sampled: 05/12/21 Time Sampled: 04:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106861					
Lead	13-MAY-2021 21:09	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:53	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Sall Sink #2 Date Sampled: 05/12/21 Time Sampled: 04:44

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106862					
Lead	13-MAY-2021 21:16	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:54	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Girls Sink #1 Date Sampled: 05/12/21 Time Sampled: 04:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106863					
Lead	13-MAY-2021 21:23	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:54	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Girs Sink #2 Date Sampled: 05/12/21 Time Sampled: 04:45

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106864					
Lead	13-MAY-2021 21:29	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:55	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

05/19/2021

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

YMCA of Vineland
1159 East Landis Avenue
Vineland, NJ 08360
856-691-0030 x 106

www.ajwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Boys Sink #1

Date Sampled: 05/12/21

Time Sampled: 04:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106865					
Lead	13-MAY-2021 21:36	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:55	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Boys Sink #2

Date Sampled: 05/12/21

Time Sampled: 04:46

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	T106866					
Lead	13-MAY-2021 21:42	<2.00	ug/L	2.0	15.5	SM3113B
Copper	18-MAY-2021 10:56	<0.050	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

05/19/2021

Date

CHAIN OF CUSTODY RECORD

Customer:	YMCA of Vineland
Contact	Gene Fleming
Address:	1159 East Landis Avenue Vineland, NJ 08360
Phone:	856-691-0030 x 106
Office:	Fax: 856-691-0120 <i>PAINTED COPPER</i>

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection		g g g	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
		Date	Time							
T10L48E	Field Reagent Blank	5/12/21	0440	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T10L48G	LITTON SINK	5/12/21	4:43A	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T10L48H	BALL SINK #1	5/12/21	4:44A	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T10L48I	BALL SINK #2	5/12/21	4:45A	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T10L48J	Garb's Sink #1	5/12/21	4:45A	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T10L48K	Garb's Sink #2	5/12/21	4:45A	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T10L48L	Boys Sink #1	5/12/21	4:46A	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
T10L48M	Boys Sink #2	5/12/21	4:46A	X		D	1 x 250	HNO3*	First Draw Lead and Copper	
				X		D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D'DRINKING WATER A/AQUEOUS S/SOIL S/SILSLUDGE G/GWGROUND WATER S/SURFACE WATER W/WWASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJW Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory	°C Yes No

Sampled by: (Print) <i>Gene Fleming</i>	Date 5/12/21	Time 12:11	Received by: (Signature) <i>[Signature]</i>	Date 5/12/21	Time 10:11
Relinquished by: (Signature) <i>[Signature]</i>	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time

